

HALIFAX

FIRE PREVENTIONS REGULATIONS FOR SPECIAL EVENTS



DISPLAY BOOTHS

- **NO** Structure or Display shall be constructed that will interfere with the buildings sprinkler system
- **NO** Structure or Display can block or interfere with Emergency Exit(s)
- Structures and Displays must allow for at least 36" of clearance from heating systems
(includes but not limited to structures / displays with roofs i.e trailers with awnings out)
- Electrical cables on the floor/ground subject to physical damage shall be protected by electrical matting or an acceptable alternative

TENTS



MAX SIZE for one location is 10ft X 10ft

(you can use multiple 10ft x 10ft tents if they are separated by 10ft)

Any tent must maintain safe clearances from any heating equipment or other potential source of ignition

Flame resistance certification **must** be **ON HAND**

The only standard code is CAN/ULC S109 - however, NFPA 701 test method 2 is accepted in this jurisdiction OR, may be treated to meet the required standards and must pass the NFPA 705 "Match test"

FIRE EXTINGUISHERS

Portable Fire Extinguishers must be installed in accordance with NFPA 10

All **TENTS & FOOD VENDORS** *must* have an up to date Fire Extinguisher

A minimum 5 lb. ABC type portable Fire Extinguisher must be installed where cooking is being done



FOOD VENDORS

- NO open flame under tents
- NO fryers under tents
- All cooking vessels shall have an appropriate fitted lid readily available while in use

MOTORIZED VEHICLES & RV'S

Vehicles used or stored inside displays are to have:

- Batteries disconnected
- Fuel tank cap locked or sealed
- All Propane tanks removed



FOR MORE DETAILED INFORMATION REFER TO THE **FIRE PREVENTION SPECIAL EVENT DOCUMENT**